



## **20U - Protective Coating Fusion-Bonded Epoxy for Water System Fittings**

Revised 11/09

# **SUBMITTAL**

(Current Revisions for All Standards Apply)

## **Protective Fusion-Bonded Epoxy Coating**

Interior and Exterior surfaces of Tyler Union watermain fittings 2"-48" shall be coated with 6-8 mil nominal thickness of protective fusion-bonded epoxy. The FBE coating is applied in accordance with and shall meet all applicable terms and provisions of ANSI/AWWA C116/A21.16-09.

The FBE coating material used by Tyler Union are tested to the requirements of and are in compliance with NSF 61. Tyler Union does not recommend FBE coated fittings for use in sewer systems.

Please contact the Tyler Union Customer Service Representative for your area to specify the coating required for your projects.